



# Certificate of Type-Examination 212330021/AA/01



Issued 15-08-2022

Replaces 212330021/AA/00  
Page 1 / 4

In compliance with the procedure specified in the **Alarm Components Scheme**, Kiwa FSS products declares that the stated alarm equipment complies with the technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 1a registration.

Product description:	Grade 2 Alarm Panel
Trademark:	Securis
Type designation:	ESEZ60500
Hardware / Software:	12 / 1.00.08
Variants:	See Annex 3

Placed on the market under the name or trademark of:

Name of the manufacturer:	Abus Security Center GmbH & Co. KG
Address:	Linker Kreuthweg 6
City:	86444 Affing
Country:	Germany

This certificate is granted to:

Name of the certificate holder:	Abus Security Center GmbH & Co. KG
Address:	Linker Kreuthweg 6
City:	86444 Affing
Country:	Germany

Ron Scheepers  
Managing director

Telefication B.V.  
Kiwa FSS Products  
Wilmsdorf 50  
Postbus 137  
7300 AC Apeldoorn  
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>

*This certificate has THREE Annexes.*



**Remarks and observations**

The following conditions are applicable:

Security grade: 2 (ESEZ60500); 3 (ESEZ70500)

Environmental class: II

Equipment class: Fixed

Power supply type: A

SPT structure: Type Z

ATS category: SP2

Factory location:

Digital Lighting Co. Ltd.

Life Safety Division, Xinmin District, Chang'an Town

Dongguan City

China

Product inspection location:

Abus Security Center GmbH & Co. KG

Linker Kreuthweg 6

Affing

Germany

**Documentation lodged for this Certificate of Type-Examination**

## Test Reports:

- CNPP: AH200083 - SCANTRONIC - i-on200FR, 09 December 2020
- CNPP: LM 20 00 64 i-on200FR\_i-onG3MM Env, 27 October 2020
- CNPP: LE 20 00 15 i-on200FR\_i-onG3MM Env, 23 November 2020
- BRE Global Ltd: P105310A\_Eaton\_ion30\_ion40\_CIE\_EN50131-3\_Issue1\_, 02 December 2016
- BRE Global Ltd: P105310C\_Eaton\_ion30\_ion40\_SPT\_EN50131-10\_Issue1\_, 07 December 2016
- BRE Global Ltd: P105310D\_Eaton\_ion30\_ion40\_SPT\_EN50136-2\_Issue1\_, 07 December 2016
- Telefication B.V.: 210401304-002-Ver. 1.00, 25 November 2021
- Telefication B.V.: P000115432-001-Ver 1.00, 14 June 2022

## Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

**Technical Standards and Specifications**

The product shows no non-compliances with:

EN 50131-10	June, 2014
EN 50131-3	March, 2009
EN 50136-2	August, 2013

**Applied Standards**

EN 50136-1+A1	November, 2018
EN 50131-6+A1	June, 2021
EN 50130-5	June, 2011
EN 50131-1+A1+A2	May, 2017
EN 50130-4+A1	October, 2014

**The product as described in this certificate includes the following type designations**

- Product description: Grade 2 Alarm Panel  
- Trademark: Secoris  
- Type designation: ESEZ60500  
- Hardware version: 12  
- Software version: 1.00.08

- Product description: Grade 3 Alarm Panel  
- Trademark: Secoris  
- Type designation: ESEZ70500  
- Hardware version: 03  
- Software version: 1.00.08